



KERALA WATER AUTHORITY

Telephone: 0484-2622576
Email: kwat@kwa.gov.in



QUALITY CONTROL DISTRICT LAB, ALUVA - 683101 WATER TEST REPORT

U/R NO: TC95522400023897F

Report Issue Date: 12.07.2024

Customer Name & Address St Joseph's Public School Thottuva Koovalpady P O	Date of Receipt of Payment	26.06.24
	Date of Sample received	02.07.24
	Sample given by	MO I/C, FHC Kodanad
	Sample Code	ALY/S/17867/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
Test performing dates : From : 10.07.24 to 12.07.24		

SLN	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part 10)-2023	1.0	0.58
2	pH at 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.08
3	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 12)-2009 (Reaffirmed 2018)	200	15.68
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988 (Reaffirmed 2019)	250	12.48
5	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2003 (Reaffirmed 2019)	1	BDL
6	Nitrate (as NO ₃)	mg/L	APHA 23rd Edition (UV Screening Method) 2017	45	5.37
7	Electrical conductivity at 25°C	micromhos/cm	IS 3025 (Part 14)-2013 (Reaffirmed 2019)	-	50

Remarks: DL - Detectable Limit
BDL - Below Detectable Limit

- NOTE: 1) The result stated above related only to the sample(s) submitted for testing by the customer.
2) The samples remain for 15 days from the end date of analysis.
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

End of Report



Issue Date: 04.10.2020
Rev. Date: 30.01.2023
Page (of 1)

QUALITY MANAGER
KWA, QUALITY CONTROL DISTRICT LAB
ERNAKULAM, ALUVA - 683 101

MANAGER
ST. JOSEPH'S PUBLIC SCHOOL
THOTTUVA, KOOVALPADY
P.O.

Self attested

PRINCIPAL
ST. JOSEPH'S PUBLIC SCHOOL
THOTTUVA



Telephone: 0474-2541575
email: qc@aluva@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, ALUVA - 683101
WATER TEST-BACTERIOLOGY REPORT

Report No: ALY/B/5291

Report Issue Date: 12.07.2024

Customer Name & Address St Joseph's Public School Thottuva Koovappady P O	Date of Receipt of Payment	26.06.24		
	Date of Sample received	02.07.24		
	Sample given by	MO I/C, FHC Kodanad		
	Sample Code	ALY/B/5291		
	Sample Name	Drinking Water		
	Sample Condition	Good		
	Source of Sample	Well		
	Sample Quantity	200ml		
Test performing dates : From : 03.07.24 to 04.07.24				
Sl No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	Present
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By

Faseela Kareem
FF

End of Report



Rev.Date : 02/06/2021

Page 1 of 1

Self attested

[Signature]

PRINCIPAL
ST. JOSEPH'S PUBLIC SCHOOL
THOTTUVA

[Signature]

MANAGER
ST. JOSEPH'S PUBLIC SCHOOL
THOTTUVA, KOOVAPPADY P O